



GURU NANAK DEV UNIVERSITY, AMRITSAR
Drug & Pollution Testing Lab

Dr. Preet Mohinder Singh Bedi
 Coordinator
 preet.pharma@gndu.ac.in

Dr. Tejinder Pal Singh Walia
 tejinder23@rediffmail.com

ANALYSIS REPORT

Reference No. : 400-23

Dated: 06.07.23

Sant Giani Gurbachan Singh
ji Khalsa Academy, Mehta
Chowk, Amritsar.

Dear Sir,

With reference to your sample of

Drinking water
04.07.2023.

submitted on

the result of analysis is as follow:

Sample No. 400

Submitted By: School's Personnel

Parameters	Units	Analysis
PH	-	7.4 ± 0.1
Hardness	mg/L	40 ± 10
TDS	mg/L	70 ± 10
Conductivity	µS/cm	108 ± 10
Turbidity	NTU	NIL
Chlorine Demand	mg/L	NIL

In any case this report cannot be used for legal purposes.

Thanking you,

Yours Sincerely,

Tejinder Pal Singh Walia
 (Dr. Tejinder Pal Singh Walia)
 [98761-97547]

Analysed by:

Tejinder Pal Singh Walia

Coordinator
 Co-ordinator
 Drug and Pollution Testing Laboratory
 Guru Nanak Dev University,
 Amritsar, 143005 Punjab.